

**ADULT COURT AND TEMPORARY HOLDING FACILITIES
PHYSICAL PLANT EVALUATION
Board of State and Community Corrections**

Applicable Title 24 Regulations: 6/94; 2/99; 2001; 2005

BSCC Code: 5345

FACILITY NAME: Watsonville Court Holding				FACILITY TYPE: CHJ	
APPLICABLE REGULATIONS (Check All That Apply):	6/94:	2/99:	2001: X	2005:	OTHER:
FIELD REPRESENTATIVE: Steve Keithley				DATE: Sept. 29 – Oct. 1, 2015	
TITLE 24 SECTION	YES	NO	N/A	COMMENTS	
Reception and Booking (2.1) Contains a weapons locker, designed as outlined in these regulations.	✓				
Contains a cell or room for confinement pending booking			✓	This is not a booking facility.	
Contains a sobering cell (WA in TH; NA in CH) 01: Name changed to “sobering cell.” 2-99: Two detoxification cells are provided if both male and female inmates are held.			✓	Sobering cells located at the Main Jail.	
Contains safety cell(s) (WA in TH; NA in CH)			✓	No cells of this type in the facility.	
Shower room available 2-99: Access to shower must be within the secure area	✓			Showerhead is not suicide-resistant. Agency has modified policy to ensure monitored showers.	
Provides secure vault or storage for inmate valuables	✓				
Telephone(s) available for inmate use (PC § 851.5)	✓				
2-99: Unobstructed access to hot and cold running water	✓				
Temporary Holding Cell or Room (2.2) Contains 10 square feet of floor area per inmate	✓				
Holds no more than 16 inmates	✓				
Is not smaller than 40 square feet and has a clear ceiling height of 8 feet or more	✓				
Contains sufficient seating to accommodate all inmates	✓				
Contains water closet (toilet), washbasin, and drinking fountain	✓				
Provides for clear visual supervision by staff	✓				
A bunk is provided if inmates are held 12 hours or more			✓	Inmates will be present during court hours.	
Temporary Staging Cell or Room (2.3)			✓	No cells of this type in the facility. The text of the regulation is removed from this checklist.	
Sobering Cell (2.4)			✓	The facility does not have a sobering cell. Inmates requiring such supervision are housed at the county jail in Santa Cruz. The text of the regulation is removed from this checklist.	
Safety Cell (2.5)			✓	The facility does not have a safety cell. Inmates requiring such supervision are housed at the mail jail in Santa Cruz. The text of the regulation is removed from this checklist.	
Safety Equipment Storage (2.19) Adequate space is provided to store equipment such as fire extinguishers, SCBA, emergency lights, etc.	✓				

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Janitors' Closet (2.20) Lockable, containing a mop sink and storage space 01: Mop sink may be separate from janitors' closet	✓			
Audio or Visual Monitoring (2.22) There is an audio monitoring system capable of alerting staff in a central control. When visual electronic surveillance is use, it is located primarily in corridors, elevators, or at points on the security perimeter such as entrances and exits. 2-99: Video monitoring option deleted.	✓			The facility has both an audio and visual monitoring system with direct feed to the control station.
Emergency Power (2.24) There is an emergency power source available and capable of providing minimal lighting in all areas and maintaining fire and life safety, security, communication and alarm systems.	✓			
Attorney Interview Space (2.26) Available and provides for confidentiality	✓			
Water Closets (Toilets)/Urinals (3.1) Provide for inmate privacy/modesty with staff being able to visual supervise; provided at a ratio of 1:16 in holding and staging cells. See regulation for calculations of urinal substitutions.	✓			All cells contain a toilet and are limited to no more than 12 inmates in the two largest cells.
Washbasins (3.2) Provide hot and cold or tempered water; provided at a ratio of 1:16 in holding and staging cells. See regulation for calculations of washbasin trough substitutions.	✓			Cells contain toilet, wash basin and drinking fountain as a single unit.
Drinking Fountains (3.3) 2-99: Available in each temporary holding, staging and sobering cell.	✓			
Water outlet (bubbler) is mechanically actuated and at an angle that prevents wastewater from flowing over the outlet (bubbler); there is a mouth guard on the water outlet (bubbler). 2-99: Mouth guard requirement deleted	✓			
Showers (3.4) (NA in CH) Available in the security area; provide hot and cold or tempered water; shower stalls/areas are designed and constructed of materials that are impervious to water and soap so that they may be easily cleaned.	✓			The facility has included a handicap access shower in the court holding area.

Beds/Bunks (3.5) (NA in CH; applicable in TH if inmates are held longer than 12 hours) At least 30 inches wide and 76 inches long with 21 inches between pans; constructed of pan bottom type or concrete; securely fastened to the floor and/or wall in facilities higher than minimum security. 01: Must be elevated off the floor.			✓	
Lighting (3.6) Lighting is sufficient to permit easy reading by a person with normal vision, night lighting is sufficient for purposes of supervision. Lighting is centrally controlled and/or occupant controlled in housing cells or rooms. Light fixtures are of secure design.	✓			
Windows (3.7) Windows that are accessible to inmates are no greater than 5 inches in on dimension.			✓	
Cell Padding (3.8) The floors and partition are padded in detoxification-sobering cells. In safety cells, floors, doors, walls and everything on them are padded. All padded cells are equipped with an tamper resistant fire sprinkler approved by the SFM.			✓	There are no padded cells in the court holding facility.
All padding is: approved for use by the SFM; nonporous; at least ½ inch thick; of a unitary or laminated construction; firmly bonded to all surfaces; and, without exposed seams.			✓	
Seating (3.10) Seating is designed to the level of security. When bench seating is used, eighteen inches of bench are provided per inmate. 2-99: In holding and staging cells, seating is securely fastened to the wall and/or floor.	✓			Poured concrete benches are in all cells.
Weapons Locker (3.12) A secure weapons locker is located outside the security perimeter of the facility and no weapons are brought into the security area. Lockers have individual compartments, locks and keys.	✓			
Design Requirements (102(c)6) Design requirements as specified in Title 24, Part 1, 102(c)6 are met. (See regulation for specific requirements. Note areas of non-compliance that are applicable to the facility type and construction date in the "comments" section.)	✓			