

**ADULT TYPE I, II, III AND IV FACILITIES
PHYSICAL PLANT EVALUATION
Board of State and Community Corrections**

Applicable Title 24 Regulations: 3/80; 8/86; 5/88; 1/91

BSCC Code: 5310

FACILITY NAME: Santa Cruz Rountree Medium					FACILITY TYPE: II	
APPLICABLE REGULATIONS (Check All That Apply):	3/80:	8/86:	5/88: ✓	1/91:	OTHER:	
FIELD REPRESENTATIVE: Steve Keithley					DATE: 2/20/2018	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Temporary Holding Cells (2.2)	✓			
Contain 10 square feet of floor per inmate	✓			
Limited to no more than 16 inmates	✓			
No smaller than 40 square feet	✓			
Contain sufficient seating to accommodate all inmates	✓			
Toilet accessible	✓			
Water fountain accessible	✓			
Wash basin accessible	✓			
Provides clear visual supervision	✓			
Telephone accessible	✓			
Weapons Locker (3.12)	✓			
External to the security area and equipped with individual compartments, locks and keys	✓			
Temporary Staging Cell or Room (2.3)			✓	These cells are not located at this facility. Balance of this regulation is deleted.
1-91: Added provision for temporary staging cells-rooms			✓	
Holds inmates classified and segregated per Title 15 § 1050 and § 1053			✓	
Detoxification/Sobering Cells (2.4)			✓	These cells are not located at this facility. Balance of this regulation is deleted.
01: Name change to "sobering cell"			✓	
Contain 20 square feet of floor per inmate			✓	
Shower-Delousing Room (3.4)			✓	
Available in reception/booking			✓	
Secure Vault or Storage Space (2.1)	✓			
Available for inmate valuables	✓			
Telephone (2.1)	✓			
Available for inmate use per Penal Code § 851.5	✓			
Safety Cells (2.5)			✓	These cells are not located at this facility. Balance of this regulation is deleted.
Contain 48 square feet with one floor dimension at least 6 feet and ceiling height of at least 8 feet			✓	
Single Occupancy Cells (2.6)			✓	These cells are not located at this facility. Balance of this regulation is deleted.
Maximum capacity of one inmate			✓	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Multiple Occupancy Cells (8227) 8-86: Deleted provision for multiple occupancy cells Contain 35 square feet per person			✓	These cells are not located at this facility. Balance of this regulation is deleted.
Multiple Occupancy Rooms (8229) 8-86: Deleted provision for multiple occupancy rooms Limited to housing persons in Type III and IV facilities and workers in Type I and II facilities			✓	These cells are not located at this facility. Balance of this regulation is deleted.
Double Occupancy Cells (2.7) 5-88: Added provision for double occupancy cells Maximum capacity of two inmates			✓	These cells are not located at this facility. Balance of this regulation is deleted.
Dormitories (2.8) 8-86: Provision for dormitories added Contain 50 square feet of floor area per inmate and a minimum of 8 feet ceiling height	✓			
Be designed for no fewer than 8 and no more than 64 inmates	✓			
Facilities having a total rated capacity of 80 inmates or less, may design dormitories for no fewer than 4 inmates	✓			
Access to toilets separate from washbasins (ratio 1:8) and drinking fountains	✓			
01: Ratio changed to 1:10				
Provide storage space for each inmates' personal items	✓			
Dayrooms (2.9) 8-86: Added requirement for 3 foot wide corridors in front of cells-rooms 99: Corridor requirement deleted	✓			
35 square feet of floor area per inmate	✓			
Contain tables and seating to accommodate the maximum number of inmates served	✓			
Access to toilets, washbasins and drinking fountains	✓			
Available to all inmates in Type II and III facilities (excluding special use cells) and to workers in Type I facilities	✓			
Shower (3.4) Available on a ratio of 1:16 01: Ratio changed to 1:20	✓			
Lighting (3.6) Sufficient to permit easy reading. Night lighting is sufficient to allow good supervision. 8-86: Specifies at least 20 foot-candles at desk level and in grooming areas, with night lighting not to exceed 5 foot-candles	✓			
Beds-Bunks (3.5) 30 inches wide and 76 inches long	✓			

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Comfortable Living Environment [102(c)6] A comfortable living environment is maintained through an adequate heating and cooling system.	✓			
Exercise Area -Type II, III and WA IV (2.10) At least one exercise area must contain a minimum of 900 square feet	✓			
8-86: Outdoor exercise area provided	✓			
8-86: Clear height of 15 feet with required surface area meeting a formula of: 80% of maximum rated inmate population and number of one-hour exercise periods per day = required surface area	✓			
Program Space - Type II and III (2.11) Sufficient area and furnishings to meet the needs of the facility programs	✓			
Dining Facilities (2.17) 15 square feet per inmate being fed	✓			
Toilets, washbasins and showers are not in the same room or not in view of inmate dining	✓			
Visiting (2.18) Sufficient visiting area	✓			
Contact visits whenever possible for minimum security inmates	✓			
Attorney Interviews (2.26) Provide for confidential attorney consultation	✓			
Safety Equipment Storage (2.19) Adequate space is provided for storage of equipment such as fire extinguishers, SCBA, emergency lights, etc.	✓			
Janitor Closet (2.20) Located in security areas lockable, containing a mop sink and storage space	✓			
Storage Rooms (2.21) Sufficient space to accommodate inmate property, bedding and supplies	✓			
Audio or Video Monitoring System -NA Type IV (2.22) Audio monitoring system capable of alerting staff in a central control	✓			Central control can monitor.
Video monitoring in corridors, main entries and/or exits and programs or activity areas	✓			

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Fire Detection and Alarm System [102(c)6] Automatic fire alarm system capable of alerting staff in a central control point	✓			
Emergency Power (2.24) Available to provide minimal lighting, maintain communications, alarm, fire, life and security systems	✓			
Provide Space for: Barber/beauty shop(2.15) 8-86: Limit requirement to Type II and III facilities 99: Requirement deleted	✓			
Canteen (2.16) 8-86: Added for II, III & IV facilities	✓			
Confidential Interview Rooms (2.25) 8-86: Added for Type II facilities	✓			