

**ADULT COURT AND TEMPORARY HOLDING FACILITIES  
PHYSICAL PLANT EVALUATION  
Board of State and Community Corrections**

**Applicable Title 24 Regulations: 6/94; 2/99; 2001; 2005**

**BSCC Code: 5345**

<b>FACILITY NAME:</b> Watsonville Court Holding				<b>FACILITY TYPE:</b> CHJ	
<b>APPLICABLE REGULATIONS (Check All That Apply):</b>	<b>6/94:</b>	<b>2/99:</b>	<b>2001: X</b>	<b>2005:</b>	<b>OTHER:</b>
<b>FIELD REPRESENTATIVE:</b> Kimberly Moule				<b>DATE:</b> September 25, 2019	
<b>TITLE 24 SECTION</b>	<b>YES</b>	<b>NO</b>	<b>N/A</b>	<b>COMMENTS</b>	
<b>Reception and Booking (2.1)</b> Contains a weapons locker, designed as outlined in these regulations.	✓				
Contains a cell or room for confinement pending booking			✓	This is not a booking facility.	
Contains a sobering cell (WA in TH; NA in CH) 01: Name changed to "sobering cell." 2-99: Two detoxification cells are provided if both male and female inmates are held.			✓	Sobering cells located at the Main Jail.	
Contains safety cell(s) (WA in TH; NA in CH)			✓	No cells of this type in the facility.	
Shower room available 2-99: Access to shower must be within the secure area	✓			Showerhead is not suicide-resistant. Agency has modified policy to ensure monitored showers.	
Provides secure vault or storage for inmate valuables	✓				
Telephone(s) available for inmate use (PC § 851.5)	✓				
2-99: Unobstructed access to hot and cold running water	✓				
<b>Temporary Holding Cell or Room (2.2)</b> Contains 10 square feet of floor area per inmate	✓				
Holds no more than 16 inmates	✓				
Is not smaller than 40 square feet and has a clear ceiling height of 8 feet or more	✓				
Contains sufficient seating to accommodate all inmates	✓				
Contains water closet (toilet), washbasin, and drinking fountain	✓				
Provides for clear visual supervision by staff	✓				
A bunk is provided if inmates are held 12 hours or more			✓	Inmates are never held longer than 12 hours.	
<b>Temporary Staging Cell or Room (2.3)</b>			✓	No cells of this type in the facility. The text of the regulation is removed from this checklist.	
<b>Sobering Cell (2.4)</b>			✓	No cell of this time in the facility.	
<b>Safety Cell (2.5)</b>			✓	No cell of this time in the facility.	
<b>Safety Equipment Storage (2.19)</b> Adequate space is provided to store equipment such as fire extinguishers, SCBA, emergency lights, etc.	✓				
<b>TITLE 24 SECTION</b>	<b>YES</b>	<b>NO</b>	<b>N/A</b>	<b>COMMENTS</b>	
<b>Janitors' Closet (2.20)</b> Lockable, containing a mop sink and storage space 01: Mop sink may be separate from janitors' closet	✓				

<b>Audio or Visual Monitoring (2.22)</b> There is an audio monitoring system capable of alerting staff in a central control. When visual electronic surveillance is use, it is located primarily in corridors, elevators, or at points on the security perimeter such as entrances and exits. 2-99: Video monitoring option deleted.	✓			The facility has both an audio and visual monitoring system with direct feed to the control station.
<b>Emergency Power (2.24)</b> There is an emergency power source available and capable of providing minimal lighting in all areas and maintaining fire and life safety, security, communication and alarm systems.	✓			
<b>Attorney Interview Space (2.26)</b> Available and provides for confidentiality	✓			
<b>Water Closets (Toilets)/Urinals (3.1)</b> Provide for inmate privacy/modesty with staff being able to visual supervise; provided at a ratio of 1:16 in holding and staging cells. See regulation for calculations of urinal substitutions.	✓			All cells contain a toilet and are limited to no more than 12 inmates in the two largest cells.
<b>Washbasins (3.2)</b> Provide hot and cold or tempered water; provided at a ratio of 1:16 in holding and staging cells. See regulation for calculations of washbasin trough substitutions.	✓			Cells contain toilet, wash basin and drinking fountain as a single unit.
<b>Drinking Fountains (3.3)</b> 2-99: Available in each temporary holding, staging and sobering cell.	✓			
Water outlet (bubbler) is mechanically actuated and at an angle that prevents wastewater from flowing over the outlet (bubbler); there is a mouth guard on the water outlet (bubbler). 2-99: Mouth guard requirement deleted	✓			
<b>Showers (3.4) (NA in CH)</b> Available in the security area; provide hot and cold or tempered water; shower stalls/areas are designed and constructed of materials that are impervious to water and soap so that they may be easily cleaned.	✓			The facility has included a handicap access shower in the court holding area.
<b>Beds/Bunks (3.5)</b> (NA in CH; applicable in TH if inmates are held longer than 12 hours)  At least 30 inches wide and 76 inches long with 21 inches between pans; constructed of pan bottom type or concrete; securely fastened to the floor and/or wall in facilities higher than minimum security.  01: Must be elevated off the floor.			✓	

<b>Lighting (3.6)</b> Lighting is sufficient to permit easy reading by a person with normal vision, night lighting is sufficient for purposes of supervision.  Lighting is centrally controlled and/or occupant controlled in housing cells or rooms. Light fixtures are of secure design.	✓			
<b>Windows (3.7)</b> Windows that are accessible to inmates are no greater than 5 inches in on dimension.			✓	
<b>Cell Padding (3.8)</b> The floors and partition are padded in detoxification-sobering cells. In safety cells, floors, doors, walls and everything on them are padded. All padded cells are equipped with an tamper resistant fire sprinkler approved by the SFM.			✓	There are no padded cells in the court holding facility.
All padding is: approved for use by the SFM; nonporous; at least ½ inch thick; of a unitary or laminated construction; firmly bonded to all surfaces; and, without exposed seams.			✓	
<b>Seating (3.10)</b> Seating is designed to the level of security. When bench seating is used, eighteen inches of bench are provided per inmate. 2-99: In holding and staging cells, seating is securely fastened to the wall and/or floor.	✓			Poured concrete benches are in all cells.
<b>Weapons Locker (3.12)</b> A secure weapons locker is located outside the security perimeter of the facility and no weapons are brought into the security area. Lockers have individual compartments, locks and keys.	✓			
<b>Design Requirements (102(c)6)</b> Design requirements as specified in Title 24, Part 1, 102(c)6 are met. (See regulation for specific requirements. Note areas of non-compliance that are applicable to the facility type and construction date in the "comments" section.)	✓			