

**ADULT TYPE I, II, III AND IV FACILITIES
PHYSICAL PLANT EVALUATION
Board of State and Community Corrections**

Applicable Title 24 Regulations: 3/80; 8/86; 5/88; 1/91

BSCC Code: 5310

| | | | | | |
|---|--------------|--------------|----------------|---------------------------------|---------------|
| FACILITY NAME: Santa Cruz Rountree Medium | | | | FACILITY TYPE: II | |
| APPLICABLE REGULATIONS (Check All That Apply): | 3/80: | 8/86: | 5/88: ✓ | 1/91: | OTHER: |
| FIELD REPRESENTATIVE: Kimberly Moule | | | | DATE: September 25, 2019 | |

| TITLE 24 SECTION | YES | NO | N/A | COMMENTS |
|---|-----|----|-----|---|
| Temporary Holding Cells (2.2) | ✓ | | | |
| Contain 10 square feet of floor per inmate | ✓ | | | |
| Limited to no more than 16 inmates | ✓ | | | |
| No smaller than 40 square feet | ✓ | | | |
| Contain sufficient seating to accommodate all inmates | ✓ | | | |
| Toilet accessible | ✓ | | | |
| Water fountain accessible | ✓ | | | |
| Wash basin accessible | ✓ | | | |
| Provides clear visual supervision | ✓ | | | |
| Telephone accessible | ✓ | | | |
| Weapons Locker (3.12) | ✓ | | | |
| External to the security area and equipped with individual compartments, locks and keys | ✓ | | | |
| Temporary Staging Cell or Room (2.3) | | | ✓ | These cells are not located at this facility. Balance of this regulation is deleted. |
| 1-91: Added provision for temporary staging cells-rooms | | | ✓ | |
| Holds inmates classified and segregated per Title 15 § 1050 and § 1053 | | | ✓ | |
| Detoxification/Sobering Cells (2.4) | | | ✓ | These cells are not located at this facility. Balance of this regulation is deleted. |
| 01: Name change to “sobering cell” | | | ✓ | |
| Contain 20 square feet of floor per inmate | | | ✓ | |
| Shower-Delousing Room (3.4) | | | ✓ | |
| Available in reception/booking | | | ✓ | |
| Secure Vault or Storage Space (2.1) | ✓ | | | |
| Available for inmate valuables | ✓ | | | |
| Telephone (2.1) | ✓ | | | |
| Available for inmate use per Penal Code § 851.5 | ✓ | | | |
| Safety Cells (2.5) | | | ✓ | These cells are not located at this facility. Balance of this regulation is deleted. |
| Contain 48 square feet with one floor dimension at least 6 feet and ceiling height of at least 8 feet | | | ✓ | |
| Single Occupancy Cells (2.6) | | | ✓ | These cells are not located at this facility. Balance of this regulation is deleted. |
| Maximum capacity of one inmate | | | ✓ | |

| TITLE 24 SECTION | YES | NO | N/A | COMMENTS |
|---|-----|----|-----|---|
| Multiple Occupancy Cells (8227) 8-86: Deleted provision for multiple occupancy cells Contain 35 square feet per person | | | ✓ | These cells are not located at this facility. Balance of this regulation is deleted. |
| Multiple Occupancy Rooms (8229) 8-86: Deleted provision for multiple occupancy rooms Limited to housing persons in Type III and IV facilities and workers in Type I and II facilities | | | ✓ | These cells are not located at this facility. Balance of this regulation is deleted. |
| Double Occupancy Cells (2.7) 5-88: Added provision for double occupancy cells Maximum capacity of two inmates | | | ✓ | These cells are not located at this facility. Balance of this regulation is deleted. |
| Dormitories (2.8) 8-86: Provision for dormitories added Contain 50 square feet of floor area per inmate and a minimum of 8 feet ceiling height | ✓ | | | |
| Be designed for no fewer than 8 and no more than 64 inmates | ✓ | | | |
| Facilities having a total rated capacity of 80 inmates or less, may design dormitories for no fewer than 4 inmates | ✓ | | | |
| Access to toilets separate from washbasins (ratio 1:8) and drinking fountains 01: Ratio changed to 1:10 | ✓ | | | |
| Provide storage space for each inmates' personal items | ✓ | | | |
| Dayrooms (2.9) 8-86: Added requirement for 3 foot wide corridors in front of cells-rooms 99: Corridor requirement deleted | ✓ | | | |
| 35 square feet of floor area per inmate | ✓ | | | |
| Contain tables and seating to accommodate the maximum number of inmates served | ✓ | | | |
| Access to toilets, washbasins and drinking fountains | ✓ | | | |
| Available to all inmates in Type II and III facilities (excluding special use cells) and to workers in Type I facilities | ✓ | | | |
| Shower (3.4) Available on a ratio of 1:16 01: Ratio changed to 1:20 | ✓ | | | |
| Lighting (3.6) Sufficient to permit easy reading. Night lighting is sufficient to allow good supervision. 8-86: Specifies at least 20 foot-candles at desk level and in grooming areas, with night lighting not to exceed 5 foot-candles | ✓ | | | |
| Beds-Bunks (3.5) 30 inches wide and 76 inches long | ✓ | | | |

| TITLE 24 SECTION | YES | NO | N/A | COMMENTS |
|---|-----|----|-----|------------------------------|
| Comfortable Living Environment [102(c)6] A comfortable living environment is maintained through an adequate heating and cooling system. | ✓ | | | |
| Exercise Area -Type II, III and WA IV (2.10) At least one exercise area must contain a minimum of 900 square feet | ✓ | | | |
| 8-86: Outdoor exercise area provided | ✓ | | | |
| 8-86: Clear height of 15 feet with required surface area meeting a formula of: 80% of maximum rated inmate population and number of one-hour exercise periods per day = required surface area | ✓ | | | |
| Program Space - Type II and III (2.11) Sufficient area and furnishings to meet the needs of the facility programs | ✓ | | | |
| Dining Facilities (2.17) 15 square feet per inmate being fed | ✓ | | | |
| Toilets, washbasins and showers are not in the same room or not in view of inmate dining | ✓ | | | |
| Visiting (2.18) Sufficient visiting area | ✓ | | | |
| Contact visits whenever possible for minimum security inmates | ✓ | | | |
| Attorney Interviews (2.26) Provide for confidential attorney consultation | ✓ | | | |
| Safety Equipment Storage (2.19) Adequate space is provided for storage of equipment such as fire extinguishers, SCBA, emergency lights, etc. | ✓ | | | |
| Janitor Closet (2.20) Located in security areas lockable, containing a mop sink and storage space | ✓ | | | |
| Storage Rooms (2.21) Sufficient space to accommodate inmate property, bedding and supplies | ✓ | | | |
| Audio or Video Monitoring System -NA Type IV (2.22) Audio monitoring system capable of alerting staff in a central control | ✓ | | | Central control can monitor. |
| Video monitoring in corridors, main entries and/or exits and programs or activity areas | ✓ | | | |

| TITLE 24 SECTION | YES | NO | N/A | COMMENTS |
|--|-----|----|-----|----------|
| Fire Detection and Alarm System [102(c)6] Automatic fire alarm system capable of alerting staff in a central control point | ✓ | | | |
| Emergency Power (2.24) Available to provide minimal lighting, maintain communications, alarm, fire, life and security systems | ✓ | | | |
| Provide Space for: Barber/beauty shop(2.15) 8-86: Limit requirement to Type II and III facilities 99: Requirement deleted | ✓ | | | |
| Canteen (2.16) 8-86: Added for II, III & IV facilities | ✓ | | | |
| Confidential Interview Rooms (2.25) 8-86: Added for Type II facilities | ✓ | | | |