

**ADULT COURT AND TEMPORARY HOLDING FACILITIES
PHYSICAL PLANT EVALUATION
Board of State and Community Corrections**

Applicable Title 24 Regulations: 6/94; 2/99; 2001; 2005

BSCC Code: 5325

FACILITY NAME: Santa Cruz Court Holding				FACILITY TYPE: CH	
APPLICABLE REGULATIONS (Check All That Apply):	6/94: <input checked="" type="checkbox"/>	2/99: <input type="checkbox"/>	2001: <input type="checkbox"/>	2005: <input type="checkbox"/>	OTHER: 1963
FIELD REPRESENTATIVE: Steve Keithley				DATE: 2/20/2018	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Reception and Booking (2.1)			<input checked="" type="checkbox"/>	Booking is performed at the Main Jail. Text of the regulation removed from this checklist.
Temporary Holding Cell or Room (2.2) Contains 10 square feet of floor area per inmate	<input checked="" type="checkbox"/>			
Holds no more than 16 inmates	<input checked="" type="checkbox"/>			
Is not smaller than 40 square feet and has a clear ceiling height of 8 feet or more	<input checked="" type="checkbox"/>			
Contains sufficient seating to accommodate all inmates	<input checked="" type="checkbox"/>			
Contains water closet (toilet), washbasin, and drinking fountain	<input checked="" type="checkbox"/>			
Provides for clear visual supervision by staff	<input checked="" type="checkbox"/>			
A bunk is provided if inmates are held 12 hours or more			<input checked="" type="checkbox"/>	
Temporary Staging Cell or Room (2.3) Holds inmates classified and segregated per Title 15 § 1050 and 1053			<input checked="" type="checkbox"/>	No cells of this type exist at this facility.
Holds inmates for four hours or less			<input checked="" type="checkbox"/>	
Limited to holding no more than 80 inmates			<input checked="" type="checkbox"/>	
Contains 10 square feet of floor area per inmates and has a clear ceiling height of 8 feet or more.			<input checked="" type="checkbox"/>	
Is at least 160 square feet			<input checked="" type="checkbox"/>	
Contains sufficient seating to accommodate all inmates			<input checked="" type="checkbox"/>	
Contains water closets (toilets), wash basins and drinking fountains as specified by these regulations			<input checked="" type="checkbox"/>	
Provides for clear visual supervision by staff			<input checked="" type="checkbox"/>	
Sobering Cell (2.4)			<input checked="" type="checkbox"/>	Sobering cell is not located in this building. Text of the regulation removed from this checklist.
Safety Cell (2.5)			<input checked="" type="checkbox"/>	Safety cell is not located in this building. Text of the regulation removed from this checklist.
Safety Equipment Storage (2.19) Adequate space is provided to store equipment such as fire extinguishers, SCBA, emergency lights, etc.	<input checked="" type="checkbox"/>			
Janitors' Closet (2.20) Lockable, containing a mop sink and storage space 01: Mop sink may be separate from janitors' closet	<input checked="" type="checkbox"/>			

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Audio or Visual Monitoring (2.22) There is an audio monitoring system capable of alerting staff in a central control. When visual electronic surveillance is use, it is located primarily in corridors, elevators, or at points on the security perimeter such as entrances and exits. 2-99: Video monitoring option deleted.	✓			
Emergency Power (2.24) There is an emergency power source available and capable of providing minimal lighting in all areas and maintaining fire and life safety, security, communication and alarm systems.	✓			
Attorney Interview Space (2.26) Available and provides for confidentiality	✓			Available at the Main Jail.
Water Closets (Toilets)/Urinals (3.1) Provide for inmate privacy/modesty with staff being able to visual supervise; provided at a ratio of 1:16 in holding and staging cells. See regulation for calculations of urinal substitutions.	✓			
Washbasins (3.2) Provide hot and cold or tempered water; provided at a ratio of 1:16 in holding and staging cells. See regulation for calculations of washbasin trough substitutions.	✓			
Drinking Fountains (3.3) 2-99: Available in each temporary holding, staging and sobering cell.	✓			
Water outlet (bubbler) is mechanically actuated and at an angle that prevents wastewater from flowing over the outlet (bubbler); there is a mouth guard on the water outlet (bubbler). 2-99: Mouth guard requirement deleted	✓			
Showers (3.4) (NA in CH) Available in the security area; provide hot and cold or tempered water; shower stalls/areas are designed and constructed of materials that are impervious to water and soap so that they may be easily cleaned.			✓	Showers available at the main jail.
Beds/Bunks (3.5) (NA in CH; applicable in TH if inmates are held longer than 12 hours) At least 30 inches wide and 76 inches long with 21 inches between pans; constructed of pan bottom type or concrete; securely fastened to the floor and/or wall in facilities higher than minimum security. 01: Must be elevated off the floor.			✓	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Lighting (3.6) Lighting is sufficient to permit easy reading by a person with normal vision, night lighting is sufficient for purposes of supervision. Lighting is centrally controlled and/or occupant controlled in housing cells or rooms. Light fixtures are of secure design.	✓			
Windows (3.7) Windows that are accessible to inmates are no greater than 5 inches in on dimension.			✓	
Cell Padding (3.8) The floors and partition are padded in detoxification-sobering cells. In safety cells, floors, doors, walls and everything on them are padded. All padded cells are equipped with an tamper resistant fire sprinkler approved by the SFM.			✓	
All padding is: approved for use by the SFM; nonporous; at least ½ inch thick; of a unitary or laminated construction; firmly bonded to all surfaces; and, without exposed seams.			✓	
Seating (3.10) Seating is designed to the level of security. When bench seating is used, eighteen inches of bench are provided per inmate. 2-99: In holding and staging cells, seating is securely fastened to the wall and/or floor.	✓			
Weapons Locker (3.12) A secure weapons locker is located outside the security perimeter of the facility and no weapons are brought into the security area. Lockers have individual compartments, locks and keys.	✓			
Design Requirements (102(c)6) Design requirements as specified in Title 24, Part 1, 102(c)6 are met. (See regulation for specific requirements. Note areas of non-compliance that are applicable to the facility type and construction date in the "comments" section.)	✓			