

**ADULT TYPE I, II, III AND IV FACILITIES  
PHYSICAL PLANT EVALUATION  
Board of State and Community Corrections**

**Applicable Title 24 Regulations: 3/80; 8/86; 5/88; 1/91**

**BSCC Code: 5310**

<b>FACILITY NAME:</b> Santa Cruz Rountree Medium					<b>FACILITY TYPE:</b> II	
<b>APPLICABLE REGULATIONS (Check All That Apply):</b>	<b>3/80:</b>	<b>8/86:</b>	<b>5/88:</b> ✓	<b>1/91:</b>	<b>OTHER:</b>	
<b>FIELD REPRESENTATIVE:</b> Ron Bertrand					<b>DATE:</b> 3/13/2013	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
<b>Temporary Holding Cells (2.2)</b>				
Contain 10 square feet of floor per inmate	✓			
Limited to no more than 16 inmates	✓			
No smaller than 40 square feet	✓			
Contain sufficient seating to accommodate all inmates	✓			
Toilet accessible	✓			
Water fountain accessible	✓			
Wash basin accessible	✓			
Provides clear visual supervision	✓			
Telephone accessible	✓			
<b>Weapons Locker (3.12)</b>				
External to the security area and equipped with individual compartments, locks and keys	✓			
<b>Temporary Staging Cell or Room (2.3)</b>				These cells are not located at this facility.
1-91: Added provision for temporary staging cells-rooms			✓	
Holds inmates classified and segregated per Title 15 § 1050 and § 1053				
Limited to holding inmates up to 4 hours			✓	
Maximum capacity of no more than 80 inmates			✓	
Contains 10 square feet of floor space per inmate and has a ceiling height of at least 8 feet			✓	
No smaller than 160 square feet			✓	
Contains seating to accommodate all inmates			✓	
Contains water closet, wash basin and drinking fountain			✓	
Provides unobstructed visual supervision of inmates by staff			✓	
<b>Detoxification/Sobering Cells (2.4)</b>				These cells are not located at this facility.
01: Name change to "sobering cell"			✓	
Contain 20 square feet of floor per inmate				
Limited to no more than 8 inmates			✓	
No smaller than 60 square feet			✓	
Contain toilet			✓	
Contain washbasin			✓	
Contain drinking fountain			✓	
Partitions or handrails located next to toilet fixture to provide support			✓	
Provide easy, unobstructed visual observation			✓	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Padding on the floor			✓	
<b>Shower-Delousing Room (3.4)</b> Available in reception/booking			✓	
<b>Secure Vault or Storage Space (2.1)</b> Available for inmate valuables	✓			
<b>Telephone (2.1)</b> Available for inmate use per Penal Code § 851.5	✓			
<b>Safety Cells (2.5)</b> Contain 48 square feet with one floor dimension at least 6 feet and ceiling height of at least 8 feet Limited to no more than one inmate			✓	These cells are not located at this facility.
Contain flush ring toilet with controls located outside the cell			✓	
Padded floor, door and walls			✓	
Equipped with variable intensity, security light, inaccessible to occupant			✓	
Vertical view panel not more than 4 inches wide and at least 24 inches long, in or adjacent to the door			✓	
Provide a food pass with lockable shutter no more than 4 inches high and located at least 30 inches above the floor			✓	
<b>Single Occupancy Cells (2.6)</b> Maximum capacity of one inmate			✓	These cells are not located at this facility.
Contain a minimum of 60 square feet of floor area in Type I facilities and 70 square feet in Type II and III facilities			✓	
Have a minimum ceiling height of 8 feet			✓	
Contain toilet, washbasin and drinking fountain			✓	
Contain a bunk, desk and seat (Desk and seat not required in Type I in later, less restrictive 1986 standards)			✓	
<b>Multiple Occupancy Cells (8227)</b> 8-86: Deleted provision for multiple occupancy cells Contain 35 square feet per person			✓	These cells are not located at this facility.
Limited to no more than 8 inmates			✓	
No smaller than 100 square feet			✓	
Minimum ceiling height of 8 feet			✓	
Water closet separate from washbasin and drinking fountain			✓	
Sufficient bunks to accommodate each occupant			✓	
Provide storage space for each occupant's personal items			✓	
<b>Multiple Occupancy Rooms (8229)</b> 8-86: Deleted provision for multiple occupancy rooms Limited to housing persons in Type III and IV facilities and workers in Type I and II facilities			✓	These cells are not located at this facility.
Contain 50 square feet of floor area per person and a minimum of 8 feet ceiling height			✓	
Limited to no more than 16 persons			✓	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Access to toilets separate from washbasins (ratio 1:8) and drinking fountains			✓	
Provide storage space for each occupant's personal items			✓	
<b>Double Occupancy Cells (2.7)</b> 5-88: Added provision for double occupancy cells  Maximum capacity of two inmates			✓	These cells are not located at this facility.
Contain a minimum of 60 square feet of floor space in Type I facilities and 70 square feet in Type II and III facilities			✓	
Have a minimum ceiling height of 8 feet and one floor dimension at least 6 feet			✓	
Contain toilet, washbasin and drinking fountain			✓	
Contain 2 bunks, 1 desk and seat (Desk and seat not required in Type I facilities)			✓	
<b>Dormitories (2.8)</b> 8-86: Provision for dormitories added  Contain 50 square feet of floor area per inmate and a minimum of 8 feet ceiling height	✓			
Be designed for no fewer than 8 and no more than 64 inmates		✓		
Facilities having a total rated capacity of 80 inmates or less, may design dormitories for no fewer than 4 inmates			✓	
Access to toilets separate from washbasins (ratio 1:8) and drinking fountains 01: Ratio changed to 1:10		✓		
Provide storage space for each inmates' personal items	✓			
<b>Dayrooms (2.9)</b>  8-86: Added requirement for 3 foot wide corridors in front of cells-rooms 99: Corridor requirement deleted	✓			
35 square feet of floor area per inmate		✓		
Contain tables and seating to accommodate the maximum number of inmates served	✓			
Access to toilets, washbasins and drinking fountains	✓			
Available to all inmates in Type II and III facilities (excluding special use cells) and to workers in Type I facilities	✓			
<b>Shower (3.4)</b>  Available on a ratio of 1:16 01: Ratio changed to 1:20		✓		
<b>Lighting (3.6)</b>  Sufficient to permit easy reading. Night lighting is sufficient to allow good supervision. 8-86: Specifies at least 20 foot-candles at desk level and in grooming areas, with night lighting not to exceed 5 foot-candles	✓			
<b>Beds-Bunks (3.5)</b>  30 inches wide and 76 inches long	✓			

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
<b>Comfortable Living Environment [102(c)6]</b>  A comfortable living environment is maintained through an adequate heating and cooling system.	✓			
<b>Exercise Area -Type II, III and WA IV (2.10)</b>  At least one exercise area must contain a minimum of 900 square feet	✓			
8-86: Outdoor exercise area provided	✓			
8-86: Clear height of 15 feet with required surface area meeting a formula of: 80% of maximum rated inmate population and number of one-hour exercise periods per day = required surface area	✓			
<b>Program Space - Type II and III (2.11)</b>  Sufficient area and furnishings to meet the needs of the facility programs	✓			
<b>Dining Facilities (2.17)</b>  15 square feet per inmate being fed	✓			
Toilets, washbasins and showers are not in the same room or not in view of inmate dining	✓			
<b>Visiting (2.18)</b>  Sufficient visiting area	✓			
Contact visits whenever possible for minimum security inmates	✓			
<b>Attorney Interviews (2.26)</b>  Provide for confidential attorney consultation	✓			
<b>Safety Equipment Storage (2.19)</b>  Adequate space is provided for storage of equipment such as fire extinguishers, SCBA, emergency lights, etc.	✓			
<b>Janitor Closet (2.20)</b>  Located in security areas lockable, containing a mop sink and storage space	✓			
<b>Storage Rooms (2.21)</b>  Sufficient space to accommodate inmate property, bedding and supplies	✓			
<b>Audio or Video Monitoring System -NA Type IV (2.22)</b>  Audio monitoring system capable of alerting staff in a central control	✓			Central control can monitor.
Video monitoring in corridors, main entries and/or exits and programs or activity areas	✓			

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
<b>Fire Detection and Alarm System [102(c)6]</b>  Automatic fire alarm system capable of alerting staff in a central control point	✓			
<b>Emergency Power (2.24)</b>  Available to provide minimal lighting, maintain communications, alarm, fire, life and security systems	✓			
<b>Provide Space for:</b>  <b>Barber/beauty shop(2.15)</b> 8-86: Limit requirement to Type II and III facilities 99: Requirement deleted	✓			
<b>Canteen (2.16)</b> 8-86: Added for II, III & IV facilities	✓			
<b>Confidential Interview Rooms (2.25)</b> 8-86: Added for Type II facilities	✓			