

**ADULT DETENTION FACILITY
LIVING AREA SPACE EVALUATION
Board of State and Community Corrections**

BSCC Code: 5345

FACILITY: Watsonville Court Holding	TYPE: CHJ	RC: 0
FIELD REPRESENTATIVE: Kimberly Moule		DATE: September 25, 2019

ROOMS							EACH ROOM					
Location	Cell Type	Applicable Standards	# Cells	EACH CELL		Total RC	DIMENSIONS (L x W x H)	FIXTURES*				
				# Beds	RC			T	U	W	F	S
6	Holding	2001	1		4	(4)	6.4 x 9 x 9	1		1	1	
Note: Cell contains two benches one 3' and one 3'6".												
5	Holding	2001	1		4	(4)	6.4 x 9x 9	1		1	1	
Note: Cell contains two benches; one 3' and one 3'6".												
4	Holding	2001	1		12	(12)	13'3 x 6'6"x 9	1		1	1	
Note: Cell contains two benches; one 13'3"; one 4'3". This is an irregular "L" shaped cell with a handicap access toilet and washbasin. Floor space calculations based on total floor space is 115 sq. ft.												
3	Holding	2001	1		4	(4)	6.4 x 9 x 9	1		1	1	
Note: Cell contains two benches; one 3' and one 3'6".												
2	Holding	2001	1		4	(4)	6.4 x 9 x 9	1		1	1	
Note: Cell contains two benches; one 3' and one 3'6".												
1	Holding	2001	1		12	(12)	13'4" x 9 x 9	1		1	1	
Note: Cell contains two benches; one 13'4" and one 5'6". This is an irregular "L" shaped cell. Floor space calculation based on total floor space is 150 sq. ft.												
2011 – Unapproved shower head in showers. Agency implemented Policy 11-13 (Watsonville Court Holding Shower) to mitigate risk.												

*T = Toilets; U = Urinals; W = Wash Basins; F = Fountains; S = Showers in unit. If "Total RC" appears in brackets (), it is not part of the facility's rated capacity. "+" indicates that capacity includes prorated air space from adjacent areas.