

**ADULT TYPE I, II, III AND IV FACILITIES
PHYSICAL PLANT EVALUATION
Board of State and Community Corrections**

Applicable Title 24 Regulations: 3/80; 8/86; 5/88; 1/91

BSCC Code: 5280

FACILITY NAME: Santa Cruz County Jail				FACILITY TYPE: II	
APPLICABLE REGULATIONS (Check All That Apply):	3/80: X	8/86:	5/88: X	1/91:	OTHER: 1976, 1994
FIELD REPRESENTATIVE: Steve Keithley				DATE: Sept. 29, 2015	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Temporary Holding Cells (2.2)				
Contain 10 square feet of floor per inmate	X			
Limited to no more than 16 inmates	X			
No smaller than 40 square feet	X			
Contain sufficient seating to accommodate all inmates	X			
Toilet accessible	X			
Water fountain accessible	X			
Wash basin accessible	X			
Provides clear visual supervision	X			
Telephone accessible	X			
Weapons Locker (3.12)				
External to the security area and equipped with individual compartments, locks and keys	X			
Temporary Staging Cell or Room (2.3)				No temporary staging cells or rooms built for this facility.
1-91: Added provision for temporary staging cells-rooms			X	
Holds inmates classified and segregated per Title 15 § 1050 and § 1053				
Limited to holding inmates up to 4 hours			X	
Maximum capacity of no more than 80 inmates			X	
Contains 10 square feet of floor space per inmate and has a ceiling height of at least 8 feet			X	
No smaller than 160 square feet			X	
Contains seating to accommodate all inmates			X	
Contains water closet, wash basin and drinking fountain			X	
Provides unobstructed visual supervision of inmates by staff			X	
Sobering Cells (2.4)				Sobering cells assessed against post 4/1973 standards, which require 15 sq. ft. per person.
01: Name change to "sobering cell"	X			
Contain 20 square feet of floor per inmate				
Limited to no more than 8 inmates			X	Limited to not more than 16 inmates – post 4/1973.
No smaller than 60 square feet	X			
Contain toilet	X			
Contain washbasin	X			
Contain drinking fountain	X			

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Partitions or handrails located next to toilet fixture to provide support	X			
Provide easy, unobstructed visual observation	X			
Padding on the floor	X			
Shower-Delousing Room (3.4) Available in reception/booking	X			
Secure Vault or Storage Space (2.1) Available for inmate valuables	X			
Telephone (2.1) Available for inmate use per Penal Code § 851.5	X			
Safety Cells (2.5) Contain 48 square feet with one floor dimension at least 6 feet and ceiling height of at least 8 feet	X			One safety cell designated solely for placement of restraint chair. During the 2012-2014 cycle the cell was renovated nullifying its use as a safety cell resulting in a non-rated designation.
Limited to no more than one inmate	X			2015 – The old safety cells was renamed the “Observation Cell” and will be used primarily for restrained inmates.
Contain flush ring toilet with controls located outside the cell	X			
Padded floor, door and walls	X			
Equipped with variable intensity, security light, inaccessible to occupant	X			
Vertical view panel not more than 4 inches wide and at least 24 inches long, in or adjacent to the door	X			
Provide a food pass with lockable shutter no more than 4 inches high and located at least 30 inches above the floor	X			
Single Occupancy Cells (2.6) Maximum capacity of one inmate	X			Single cells in North and South constructed under the 1994 standards. Some single cells have been converted to double cells.
Contain a minimum of 60 square feet of floor area in Type I facilities and 70 square feet in Type II and III facilities	X			
Have a minimum ceiling height of 8 feet	X			
Contain toilet, washbasin and drinking fountain	X			
Contain a bunk, desk and seat (Desk and seat not required in Type I in later, less restrictive 1986 standards)	X			
Multiple Occupancy Cells (8227) 8-86: Deleted provision for multiple occupancy cells Contain 35 square feet per person	X			All multiple cells are assessed against the 1980 standards.
Limited to no more than 8 inmates	X			
No smaller than 100 square feet	X			
Minimum ceiling height of 8 feet	X			
Water closet separate from washbasin and drinking fountain	X			
Sufficient bunks to accommodate each occupant	X			
Provide storage space for each occupant's personal items	X			
Multiple Occupancy Rooms (8229) 8-86: Deleted provision for multiple occupancy rooms Limited to housing persons in Type III and IV facilities and workers in Type I and II facilities			X	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Contain 50 square feet of floor area per person and a minimum of 8 feet ceiling height			X	
Limited to no more than 16 persons			X	
Access to toilets separate from washbasins (ratio 1:8) and drinking fountains			X	
Provide storage space for each occupant's personal items			X	
Double Occupancy Cells (2.7) 5-88: Added provision for double occupancy cells Maximum capacity of two inmates	X			Some single cells in North and South Housing have been converted to double cells.
Contain a minimum of 60 square feet of floor space in Type I facilities and 70 square feet in Type II and III facilities	X			
Have a minimum ceiling height of 8 feet and one floor dimension at least 6 feet	X			
Contain toilet, washbasin and drinking fountain	X			
Contain 2 bunks, 1 desk and seat (Desk and seat not required in Type I facilities)	X			
Dormitories (2.8) 8-86: Provision for dormitories added Contain 50 square feet of floor area per inmate and a minimum of 8 feet ceiling height	X			
Be designed for no fewer than 8 and no more than 64 inmates	X			
Facilities having a total rated capacity of 80 inmates or less, may design dormitories for no fewer than 4 inmates	X			
Access to toilets separate from washbasins (ratio 1:8) and drinking fountains 01: Ratio changed to 1:10		X		Crowding in "D" unit left 18 inmates on bunks in the dayroom (treated as a dorm in this instance.) A single toilet was available for the inmates, falling short of the 1:10 minimum ratio.
Provide storage space for each inmates' personal items	X			
Dayrooms (2.9) 8-86: Added requirement for 3 foot wide corridors in front of cells-rooms 99: Corridor requirement deleted 35 square feet of floor area per inmate		X		Triple bunks in dayrooms reduce available space for inmates. At 2014-2016 inspection, dayroom bunks were occupied in A, D, F & G units. The facility exceeded its rated capacity for 10 of 12 months in 2014. Female inmates from the "G" unit who reside on dayroom bunks are removed to a holding area while single/double celled inmates use the "G" unit dayroom.
Contain tables and seating to accommodate the maximum number of inmates served		X		
Access to toilets, washbasins and drinking fountains	X			
Available to all inmates in Type II and III facilities (excluding special use cells) and to workers in Type I facilities	X			
Shower (3.4) Available on a ratio of 1:16 01: Ratio changed to 1:20		X		Crowding in "D" unit left two showers for 42 inmates, falling short of the 1:20 ratio. The "F" Unit had 41 inmates for 2 showers and the "G" unit had a single shower for 30 inmates.

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Lighting (3.6) Sufficient to permit easy reading. Night lighting is sufficient to allow good supervision. 8-86: Specifies at least 20 foot-candles at desk level and in grooming areas, with night lighting not to exceed 5 foot-candles	X			
Beds-Bunks (3.5) 30 inches wide and 76 inches long	X			
Comfortable Living Environment [102(c)6] A comfortable living environment is maintained through an adequate heating and cooling system.	X			
Exercise Area -Type II, III and WA IV (2.10) At least one exercise area must contain a minimum of 900 square feet			X	Variance granted by Board of Corrections action 2/9/93.
8-86: Outdoor exercise area provided	X			
8-86: Clear height of 15 feet with required surface area meeting a formula of: 80% of maximum rated inmate population and number of one-hour exercise periods per day = required surface area	X			
Program Space - Type II and III (2.11) Sufficient area and furnishings to meet the needs of the facility programs	X			
Dining Facilities (2.17) 15 square feet per inmate being fed	X			
Toilets, washbasins and showers are not in the same room or not in view of inmate dining	X			
Visiting (2.18) Sufficient visiting area	X			
Contact visits whenever possible for minimum security inmates	X			
Attorney Interviews (2.26) Provide for confidential attorney consultation	X			
Safety Equipment Storage (2.19) Adequate space is provided for storage of equipment such as fire extinguishers, SCBA, emergency lights, etc.	X			
Janitor Closet (2.20) Located in security areas lockable, containing a mop sink and storage space	X			

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Storage Rooms (2.21) Sufficient space to accommodate inmate property, bedding and supplies	X			
Audio or Video Monitoring System -NA Type IV (2.22) Audio monitoring system capable of alerting staff in a central control	X			
Video monitoring in corridors, main entries and/or exits and programs or activity areas	X			
Fire Detection and Alarm System [102(c)6] Automatic fire alarm system capable of alerting staff in a central control point	X			
Emergency Power (2.24) Available to provide minimal lighting, maintain communications, alarm, fire, life and security systems	X			
Provide Space for: Barber/beauty shop(2.15) 8-86: Limit requirement to Type II and III facilities 99: Requirement deleted	X			
Canteen (2.16) 8-86: Added for II, III & IV facilities	X			
Confidential Interview Rooms (2.25) 8-86: Added for Type II facilities	X			