

**ADULT TYPE I, II, III AND IV FACILITIES
PHYSICAL PLANT EVALUATION
Board of State and Community Corrections**

Applicable Title 24 Regulations: 3/80; 8/86; 5/88; 1/91

BSCC Code: 5320

FACILITY NAME: Santa Cruz Blaine Women's Minimum				FACILITY TYPE: III	
APPLICABLE REGULATIONS (Check All That Apply):	3/80: ✓	8/86:	5/88:	1/91:	OTHER:
FIELD REPRESENTATIVE: Ron Bertrand				DATE: 3/13/2013	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Temporary Holding Cells (2.2) Contain 10 square feet of floor per inmate Limited to no more than 16 inmates No smaller than 40 square feet Contain sufficient seating to accommodate all inmates Toilet accessible Water fountain accessible Wash basin accessible Provides clear visual supervision Telephone accessible			✓	These cells are not located at this facility.
Weapons Locker (3.12) External to the security area and equipped with individual compartments, locks and keys			✓	Weapons are prohibited inside this facility. Armed officers store their weapon at the Main Jail.
Temporary Staging Cell or Room (2.3) 1-91: Added provision for temporary staging cells-rooms Holds inmates classified and segregated per Title 15 § 1050 and § 1053 Limited to holding inmates up to 4 hours Maximum capacity of no more than 80 inmates Contains 10 square feet of floor space per inmate and has a ceiling height of at least 8 feet No smaller than 160 square feet Contains seating to accommodate all inmates Contains water closet, wash basin and drinking fountain Provides unobstructed visual supervision of inmates by staff			✓	These cells are not located at this facility.
Sobering Cells (2.4) 01: Name change to "sobering cell" Contain 20 square feet of floor per inmate Limited to no more than 8 inmates No smaller than 60 square feet Contain toilet Contain washbasin Contain drinking fountain Partitions or handrails located next to toilet fixture to provide support Provide easy, unobstructed visual observation			✓	These cells are not located at this facility.

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Padding on the floor			✓	
Shower-Delousing Room (3.4) Available in reception/booking			✓	
Secure Vault or Storage Space (2.1) Available for inmate valuables	✓			Locked storeroom
Telephone (2.1) Available for inmate use per Penal Code § 851.5	✓			
Safety Cells (2.5) Contain 48 square feet with one floor dimension at least 6 feet and ceiling height of at least 8 feet			✓	These cells are not located at this facility.
Limited to no more than one inmate			✓	
Contain flush ring toilet with controls located outside the cell			✓	
Padded floor, door and walls			✓	
Equipped with variable intensity, security light, inaccessible to occupant			✓	
Vertical view panel not more than 4 inches wide and at least 24 inches long, in or adjacent to the door			✓	
Provide a food pass with lockable shutter no more than 4 inches high and located at least 30 inches above the floor			✓	
Single Occupancy Cells (2.6) Maximum capacity of one inmate			✓	These cells are not located at this facility.
Contain a minimum of 60 square feet of floor area in Type I facilities and 70 square feet in Type II and III facilities			✓	
Have a minimum ceiling height of 8 feet			✓	
Contain toilet, washbasin and drinking fountain			✓	
Contain a bunk, desk and seat (Desk and seat not required in Type I in later, less restrictive 1986 standards)			✓	
Multiple Occupancy Cells (8227) 8-86: Deleted provision for multiple occupancy cells			✓	These cells are not located at this facility.
Contain 35 square feet per person			✓	
Limited to no more than 8 inmates			✓	
No smaller than 100 square feet			✓	
Minimum ceiling height of 8 feet			✓	
Water closet separate from washbasin and drinking fountain			✓	
Sufficient bunks to accommodate each occupant			✓	
Provide storage space for each occupant's personal items			✓	
Multiple Occupancy Rooms (8229) 8-86: Deleted provision for multiple occupancy rooms	✓			Each floor is rated as a multiple occupancy room under the 1980 standards.
Limited to housing persons in Type III and IV facilities and workers in Type I and II facilities				
Contain 50 square feet of floor area per person and a minimum of 8 feet ceiling height	✓			
Limited to no more than 16 persons	✓			

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Access to toilets separate from washbasins (ratio 1:8) and drinking fountains	✓			
Provide storage space for each occupant's personal items	✓			
Double Occupancy Cells (2.7) 5-88: Added provision for double occupancy cells Maximum capacity of two inmates			✓	These cells are not located at this facility.
Contain a minimum of 60 square feet of floor space in Type I facilities and 70 square feet in Type II and III facilities			✓	
Have a minimum ceiling height of 8 feet and one floor dimension at least 6 feet			✓	
Contain toilet, washbasin and drinking fountain			✓	
Contain 2 bunks, 1 desk and seat (Desk and seat not required in Type I facilities)			✓	
Dormitories (2.8) 8-86: Provision for dormitories added Contain 50 square feet of floor area per inmate and a minimum of 8 feet ceiling height			✓	These cells are not located at this facility.
Be designed for no fewer than 8 and no more than 64 inmates			✓	
Facilities having a total rated capacity of 80 inmates or less, may design dormitories for no fewer than 4 inmates			✓	
Access to toilets separate from washbasins (ratio 1:8) and drinking fountains 01: Ratio changed to 1:10			✓	
Provide storage space for each inmates' personal items			✓	
Dayrooms (2.9) 8-86: Added requirement for 3 foot wide corridors in front of cells-rooms 99: Corridor requirement deleted	✓			
35 square feet of floor area per inmate	✓			
Contain tables and seating to accommodate the maximum number of inmates served	✓			
Access to toilets, washbasins and drinking fountains	✓			
Available to all inmates in Type II and III facilities (excluding special use cells) and to workers in Type I facilities	✓			
Shower (3.4) Available on a ratio of 1:16 01: Ratio changed to 1:20	✓			
Lighting (3.6) Sufficient to permit easy reading. Night lighting is sufficient to allow good supervision. 8-86: Specifies at least 20 foot-candles at desk level and in grooming areas, with night lighting not to exceed 5 foot-candles	✓			
Beds-Bunks (3.5) 30 inches wide and 76 inches long	✓			

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Comfortable Living Environment [102(c)6] A comfortable living environment is maintained through an adequate heating and cooling system.	✓			
Exercise Area -Type II, III and WA IV (2.10) At least one exercise area must contain a minimum of 900 square feet	✓			
8-86: Outdoor exercise area provided	✓			
8-86: Clear height of 15 feet with required surface area meeting a formula of: 80% of maximum rated inmate population and number of one-hour exercise periods per day = required surface area	✓			
Program Space - Type II and III (2.11) Sufficient area and furnishings to meet the needs of the facility programs	✓			
Dining Facilities (2.17) 15 square feet per inmate being fed	✓			
Toilets, washbasins and showers are not in the same room or not in view of inmate dining	✓			
Visiting (2.18) Sufficient visiting area	✓			
Contact visits whenever possible for minimum security inmates	✓			
Attorney Interviews (2.26) Provide for confidential attorney consultation	✓			
Safety Equipment Storage (2.19) Adequate space is provided for storage of equipment such as fire extinguishers, SCBA, emergency lights, etc.	✓			
Janitor Closet (2.20) Located in security areas lockable, containing a mop sink and storage space	✓			
Storage Rooms (2.21) Sufficient space to accommodate inmate property, bedding and supplies	✓			
Audio or Video Monitoring System -NA Type IV (2.22) Audio monitoring system capable of alerting staff in a central control			✓	Not required for Type III facilities.
Video monitoring in corridors, main entries and/or exits and programs or activity areas			✓	

TITLE 24 SECTION	YES	NO	N/A	COMMENTS
Fire Detection and Alarm System [102(c)6] Automatic fire alarm system capable of alerting staff in a central control point	✓			
Emergency Power (2.24) Available to provide minimal lighting, maintain communications, alarm, fire, life and security systems	✓			
Provide Space for: Barber/beauty shop(2.15) 8-86: Limit requirement to Type II and III facilities 99: Requirement deleted	✓			
Canteen (2.16) 8-86: Added for II, III & IV facilities	✓			
Confidential Interview Rooms (2.25) 8-86: Added for Type II facilities			✓	